

20 May 2010

Mr Dennis Mee
The Spacer Company
PO Box 279
Sumner Park Qld 4074

Dear Dennis

USE OF CONDUIT SPACERS ON THE ENERGEX NETWORK

Further to your submission seeking our comments on your products, we are pleased to advise you that the following items are suitable for use on the ENERGEX Network provided full regard and due care is taken to the backfilling material flowing continuously and evenly around all conduits.

Product Description	Details
Conduit Spacer	100 mm
Conduit Spacer	125 mm
Conduit Spacer	150 mm
Conduit Hold Downs	
Conduit Spacer Hold Downs	

Yours sincerely

Roy English
Network Engineering Standards Manager



Enquiries
Roy English
Telephone
(07) 3407 4829
Facsimile
(07) 3407 4501
Email
royenglish
@energex.com.au

Corporate Office
150 Charlotte Street
Brisbane Qld 4000
GPO Box 1461
Brisbane Qld 4001
Telephone (07) 3407 4000
Facsimile (07) 3407 4609
www.energex.com.au

ENERGEX Limited
ABN 40 078 849 055